

To: Nelson City Council

1. Issued by (Plumber/Plumbing Company):

In respect of Building Consent Number: _____

Building Consent Application: _____

Project Address: _____

Description of Work: _____

I have been engaged to undertake the plumbing work on the above building consent. I hereby certify that the work complies with the building consent and that I have undertaken a pressure test for water tightness in accordance with (tick as applicable):

- NZ Building Code G12/AS1 – 1500 kPa for a period of not less than 15 minutes
- AS/NZS 3500.5:2012 – 1500 kPa for a period of not less than 30 minutes
- Proprietary brand system with specific testing requirements:

Brand: _____

Test requirements: _____

- Manufacturer's testing forms provided

2. Plumber's Details (Plumber):

Registration No: _____

Qualification: _____

Address: _____

Phone: _____

I hereby state that the work described in this building consent has been carried out by me or my employee, and that the employee holds:

- a) A current license under part 2 of the Plumbers Gasfitters and Drainlayers Act 2006; OR
- b) A limited certificate under section 14 of the Plumbers Gasfitters and Drainlayers Act 2006 and that the person is under direct supervision of a craftsman plumber.

Signature: _____ Date: _____

Witness: _____ Date: _____

**NELSON CITY COUNCIL
WATER SUPPLY PRESSURE TEST CERTIFICATE GUIDELINES**

The purpose of the Water Supply Pressure Test Certificate is to provide Nelson City Council with a permanent record of pressure test results for the respective building consent. The certificate also confirms that the plumbing work has been completed, or supervised by a craftsman plumber in accordance with the Plumbers Gasfitters and Drainlayers Act 2006.

- a) The pressure test certificate is required to be completed by the craftsman plumber and issued to Nelson City Council for all water supply installations subject to building consent where the water supply test has not been recorded by a Nelson City Council Building Inspector.
- b) The certificate shall be witnessed by a person not employed by the Craftsman Plumber or the plumbing company or related to the craftsman plumber. Builder or owner/owner's agent is an acceptable example.
- c) Please ensure that the pressure testing method is specified and attached to this certificate any proprietary brand manufacturers test certificates where manufacturer requires them as part of their quality control regime.
- d) Where a property is serviced by a low pressure or tank supply please describe the test regime used.

Please contact the Building Inspection Team with any queries relating to this form.

Building Inspection Team
03 5460334